

Quick Reference - Fire Protection Systems

| System | 6-Month | Annual | 5-Year | Form/Standard |
|--|---------|--------|--------|-----------------------------|
| Fire Alarm System | | X | | NFPA 72 |
| Automatic Fire Sprinkler System | | X | X | CSFM-AES 2 |
| Standpipe | | X | X | CSFM-AES 3 |
| Fire Pump | | X | | CSFM-AES 5 |
| Special Suppression System/Clean Agent/CO2 | X | | | CSFM-AES 22 |
| Spray Booth | | X | | CSFM-AES 7 |
| Private Fire Service Main | | X | X | CSFM-AES 4 |
| Water Storage Tank | | X | X* | CSFM-AES 6 |
| Kitchen Hood Suppression System | X | | | CSFM-AES 20 |
| Dry Chemical System | X | | | CSFM-AES 21 |
| Active Smoke Control System | | X | | NFPA 92 |
| Emergency Generator | | X | | NFPA 110 |
| Fire Escape | | | X | NFPA 80 |
| Fire Doors | | X | | NFPA 80 |
| Emergency Responder Radio Coverage System | | X | | Manufacturer Specifications |

*5-year report may be submitted as an attachment to the annual report on AES 6